








Number	17-003747-PR02 (NW-A01-020310-en-02)
Owner	VEKA AG Dieselstr. 8 48324 Sendenhorst Germany
Product	Double tilt and turn window
Designation	System: SOFTLINE 76 Shipping name: test specimen 1.2.1
Details	Manufacturer: VEKA AG, - Sendenhorst; Material: Polyvinyl Chloride unplasticized (PVC-U) white; Opening direction: Active casement DIN left (opening) to the inside, Inactive casement DIN right (opening) to the inside; Overall dimensions (W x H): 2084 mm x 2476 mm
Special features	

Result

Requirements according to ift-Guideline FE-13/1:2011-04 fulfilled

Air permeability according to EN 12207:2016-12	Resistance to wind load according to EN 12210:2016-03	Watertightness according to EN 12208:1999-11	Behaviour between different climates - Designs being sensitive to deformation	Operating forces according to EN 13115:2001-07	Mechanical properties according to EN 13115:2001-07	Determination of the tightness of the corner joint according to ift-Richtlinie FE-13/1 2011-04
						
4	C2/B2	7A	ok	1	4	ok

ift Rosenheim
01.10.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing




Maximilian Denk
Operating Testing Officer
Building Component Testing

Basis *)

RAL GZ 716: 2013-04
EN 14351-1:2006+A2:2016-09
ift-Richtlinie FE-13/1 2011-04
*) and corresponding national versions
e.g. DIN EN
Test report: 17-003747-PR02 PB-A01-020310-de-02
Replaces ift-Nachweis:
17-003747-PR02 NW-A01-020310-en-01 dated 07.06.2018.

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

The element is made of class A profiles according to EN 12608: 2003 wall thicknesses of the main profile

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: D39-74E01