







Number	17-003747-PR11 (NW-A01-0203-en-01)
Owner	VEKA AG Dieselstr. 8 48324 Sendenhorst Germany
Product	Parallel tilting sliding door
Designation	System: SOFTLINE 76 AD Shipping name: test specimen pk 10 type 2.1
Details	Manufacturer VEKA AG, - Sendenhorst; Material Polyvinyl Chloride unplasticized (PVC-U) white; Type of opening Parallel sliding tilting; Opening direction To the right (seen from inside); Overall dimensions (W x H) 2602 mm x 2476 mm
Special features	*) extended test procedure with classification of tightness after durability test, mechanical test and additional wind load. **) The test specimen has been down graded according to client's request.


## Result

Air permeability according to EN 12207:2016-12	Resistance to wind load according to EN 12210:2016-03	Watertightness according to EN 12208:1999-11	Operating forces according to EN 13115:2001-07	Mechanical properties according to EN 13115:2001-07	Mechanical durability according to EN 12400:2002-10
					
4 <sup>*)</sup>	C1/B2	9A <sup>*)**)</sup>	1	4	2

ift Rosenheim  
18.10.2019



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Daniel Gromotka, B.Eng.  
Operating Testing Officer  
Building Component Testing

## Basis \*)

EN 14351-1:2006-03  
RAL GZ 716: 2018-07  
\*) and corresponding national versions e.g. DIN EN  
Test report: 17-003747-PR11 PB-A01-0203-de-01

## Representation



## Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

## Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

## Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies. The cover sheet can be used as abstract.

## Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: A62-B11A4